



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

January 19, 2021

ADDENDUM # 1

Bid Number: 50-00132979

Bid Opening Date: January 26, 2021

Description of Bid: LABOR, MATERIALS, AND EQUIPMENT NEEDED TO PROVIDE AND INSTALL AN AUTOMATIC PLC TRANSFER SWITCH CONTROL UPGRADE AT JEFFERSON PARISH CENTRAL PLANT FOR THE DEPARTMENT OF GENERAL SERVICES

Clarification of Specifications:

To schedule a site visit contact Eric Folsie, with the Department of General Services, by phone at either of the following phone numbers:

Office (504) 364-3460
Cell (504) 800-9259

Questions and Answers:

Q1: We would like to get any additional information (documents / drawings / etc.) for the following existing items?

- PLC
- Voltage relays
- MCC
- ATS
- Sequence of Operation
- Printout or PDF of the existing PLC program

A1: There is no additional information or drawings on these items. Bidders can visit the site and gather their own information.

Q2: What are the PLC IO types and quantities needed for the new system? (Note: If you have PLC drawings for the existing system to share, we can likely determine this from them)

A2: There is no additional information or drawings on these items. Bidders can visit the site and gather their own information.

Q3: Will the new PLC / HMI communications only be locally connected to each other, or will they have to connect to a site network?

A3: Locally connected

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

Q4a: Is there an existing 24VDC power source for the HMI, as specified in the bid request?

A4a: No

Q4b: or will one need to be provided?

A4b: If needed the vendor must supply it.

Q5: Will we be permitted to install the HMI in the MCC door prior to the actual cutover outage event?

A5: As long as it does not affect the daily operations of the building.

Q6: Will we be permitted to mount the PLC in the MCC prior to the actual cutover outage event?

A6: As long as it does not affect the daily operations of the building.

Sincerely,

Melissa Ovalle

Melissa Ovalle
Buyer II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET